

DATE: JUNE 16, 2020










SCALE: NOT TO SCALE

ON-STREET DINING
CONCEPTUAL DRAWING

NOTES:

1. ACCESSIBLE ROUTE IS MIN. 48" IN WIDTH AND MIN. 60" EVERY 200 FT FOR PASSING SPACE. CROSS SLOPE MAX. 2.0% AND RUNNING SLOPE MAX. 5.0% MAX. WHERE POSSIBLE.
2. RAMPS WITHIN THE ACCESSIBLE ROUTE (SIDEWALK TO ROADWAY) ARE REQUIRED TO HAVE CONTINUOUS EDGE PROTECTION ON BOTH SIDES OF RAMP.
3. SLOPED PEDESTRIAN ACCESS ROUTES WITH SLOPE EXCEEDING 5.0% ARE REQUIRED TO HAVE HANDRAILS AT BOTH SIDES.
4. A MIN. OF 5% OF THE TOTAL DINING TABLES PROVIDED, BUT IN NO CASE LESS THAN (1) OF EACH TYPE OF DINING TABLE SHALL BE ACCESSIBLE TO PEOPLE WITH DISABILITIES. IF A RESTAURANT PROVIDES OUTDOOR DINNING, THE 5% MIN. APPLIES TO EACH TYPE OF DINNING PROVIDED FOR THAT SPECIFIC RESTAURANT (BOOTH, INDIVIDUAL TABLES, GROUP/FAMILY STYLE TABLES)
5. TABLE SURFACE HEIGHT RANGE 28" TO 34" ABOVE GROUND. KNEE CLEARANCE MIN. 27" HIGH, 19" DEEP AND 30" WIDE BETWEEN ELEMENTS.
6. GRIND OR REPAIR ABRUPT CHANGES OF 1/2" OR MORE IN ACCESSIBLE ROUTE, OR CHANGES OF 1/4" TO 1/2" WITH NO BEVEL.
7. PROVIDE MIN. 60" TURNING SPACE AT PLATFORM/RAMP WHERE PEDESTRIANS HAVE CHANGE OF DIRECTION.

LEGEND:

-  ACCESSIBLE ROUTE
-  STREET BARRICADE
-  DINING TABLE
-  ACCESSIBLE DINING TABLE
-  ACCESSIBLE RAMP
-  "IN" ROUTE
-  "OUT" ROUTE
-  EXISTING TREE
-  EXISTING CURB RAMP